

Water Treatment Operators
14615 N. Fountain Hills Blvd.
Fountain Hills, AZ 85268

Project: Western Sky RV Air Park 15121
Project Number: 15121
Project Manager: Joseph Fiano

Reported:
01/15/25 16:39

RTCR001 (38332 Comanche Blvd) (25A0793-01) Drinking Water (Grab) Sampled: 01/07/25 08:35 Received: 01/07/25 14:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Analyst	Method	Notes
Legend Technical Services of Arizona, Inc.										
Microbiology										
E. coli	Absent	P/A	1	B5A0375	01/07/25 17:10	01/08/25 11:10	AJP	SM 9223B		
Total Coliforms	Absent	P/A	1	B5A0375	01/07/25 17:10	01/08/25 11:10	AJP	SM 9223B		

P/S Plant (EPDS001) (25A0793-02) Drinking Water (Grab) Sampled: 01/07/25 08:15 Received: 01/07/25 14:45

Analyte	Result	PQL	Units	Dilution	Batch	Prepared	Analyzed	Analyst	Method	Notes
Legend Technical Services of Arizona, Inc.										

Inorganic Chemistry

Nitrate as N	3.11	0.25	mg/L	1	B5A0230	01/08/25 08:00	01/08/25 11:05	JF	EPA 300.0
--------------	------	------	------	---	---------	----------------	----------------	----	-----------